

FEATURES & BENEFITS

CONSTRUCTION

FDA approved high-density green polyethylene tank provides the light and durable construction required in a portable unit.

MOUNTING/HEATER

J-shaped stainless steel wall bracket makes for a well constructed portable mount for easy removal and re-mount. 1000 Watt, 120VAC submersible thermostatically controlled heater and insulation jacket keep water at an ideal temperature for the irrigation process.

MOUNTING

J-shaped stainless steel wall bracket makes for a well constructed portable mount for easy removal and re-mount.

EYEWASH

Pulling down the eyewash arm will begin flushing the 16 gallon portable at .4 gpm (1.5 L) during the required 15 minutes, creating a full patterned flushing of the eyes.

DESIGN

Tank comes complete with a wide-fill opening and threaded cap for quick inspection, cleaning, and filling. Unit also comes equipped with top and side handles making relocation easy.



SPECIFICATIONS

Model 7500EB heated portable gravity operated eyewash shall include an FDA approved high-density green polyethylene 16 gallon (60.6 L) tank, ABS plastic eyewash heads with .4 gpm (1.5 L) flow rate over 15 minutes, yellow pull-down activation arm, integral handles on top and sides, and wide-fill threaded cap. Unit shall also include 1000 Watt, 120VAC submersible thermostatically controlled heater with a fitted insulating jacket which maintains a 70° F (21.1 L) water temperature with as low as -30° F (-34.4° C) ambient temperatures, 9' (274.3 cm) power cord, label-mounted operation and maintenance instructions, and stainless steel wall bracket. Additive not included - Order separately.


APPLICATIONS

Where the eyes of any person may be exposed to injurious or corrosive materials, when suitable facilities for quick flushing of the eyes needs to be provided and a continuous supply of water is not available. Although the 7500EB may be installed in a wide variety of locations, it is ideal for the remote and low traffic areas where protective measures are still needed. Emergency eyewash facilities shall be in unobstructed and accessible locations that require no more than 10 seconds for the injured person to reach. Model 7500EB is certified by CSA to meet the ANSI Z358.1 Standard for Emergency Eyewashes.

OPTIONS

- ❑ Water Additive: Model 9082, 'sterile' bacteriostatic preservative for use in portable eyewash stations. One 5 oz. (148 ml) bottle will preserve 5 to 20 gallons (18.9 to 75.7 L) of potable water for up to three months. Four bottles per carton.
- ❑ Waste Container: Model 9009 is a twenty-gallon (75.7 L) wastewater container constructed of tough yellow polymer resin. Unit is used to collect water during weekly testing of emergency equipment.

For more information, visit www.hawscos.com or call (888) 640-4297.



NOTES:

1. TO COMPLY WITH ANSI Z358.1-2009 FOR EMERGENCY EYEWASH OR EYE/FACE WASH AND SHOWER EQUIPMENT:
 - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURE'S INSTRUCTIONS AND ACCPTABLE PLUMBING PRACTICES
 - EYEWASH OR EYE/FACE WASH SHALL BE POSITIONED WITH NOZZLES NOT LESS THAN 83.8 CM (33 IN.) AND NO GREATER THAN 114.2 CM (45 IN) FROM SURFACE WHICH USER STANDS AND (15.3 CM (6 IN.) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.
2. UNIT MUST BE LEVEL FROM FRONT TO BACK AND SIDE TO SIDE
3. ALL THREE MOUNTING HOLES ON MOUNTING BRACKET MUST BE USED TO PROPERLY SECURE EYEWASH UNIT TO WALL.
4. ****UNIT MUST BE FILLED WITH WATER BEFORE CONNECTING TO POWER SOURCE.**
5. PRIOR TO SERVICING/CLEANING: UNPLUG POWER CORD ON UNIT FROM POWER SOURCE AND REMOVE UNIT FROM MOUNTING BRACKET.
6. *DIMENSIONS MAY VARY $\pm 1/2$ " (12.7mm)

				1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM			
				MODEL(S) 7500EB PORTABLE EYEWASH WITH HEATER			
ECN NO. REVISED PER BY:	ECN: 5122	WK		PART NUMBER			
DRAWN: TRF	DATE: 06/06/90	CHK'D: JP		0002080059.D			
APPROVED: FV	DATE: 07/28/16			REVISION			
				14			
SCALE: 1:1		DRAWING TYPE: INSTALLATION		SIZE: A		SHEET 1 OF 1	